

Human Physiology Tenant Improvement at Hayward Field

REQUEST FOR PLANNED SHUTDOWN

****Submitting this requests implies that the requestor has coordinated with ALL applicable trades.****

Shutdown Type:

Panel NW-LPC-2 shutdown for HPTI temp power removal.

Spaces and/or Buildings Impacted:

Branch circuiting in panel NW-LPC-2 and sub fed panel NW-LCA.

Shutdown Time & Date:

From	7:30am	am/pm	4/28/2021	(mm/dd/yy)
To	8:30am	am/pm	4/28/2021	(mm/dd/yy)

Reason for Shutdown:

Temp power feeder removal for HPTI space. 200A breaker to be left in panel as spare.

Special Conditions Affecting Shutdown or Building Occupants:

See attached NW-LPC-2 panel schedule for specific circuits affected.

Work Performed By: Kyle Hansen - JKG Electric **Contact #** 541-214-0897

Notice Submitted By: Daniel Wilson - JKG Electric **Date:** 4/12/2021

Authorization to Proceed with Shutdown:

UO Project Manager: _____ Date: _____

*****EMERGENCY CONTACTS*****

CONTRACTOR:

Kyle Hansen - JKG Electric	541-214-0897
Mike Hansen- Superintendent	541.537.2328
x - Project Engineer	phone number

UNIVERSITY OF OREGON:

Gene Mowery, Owner's Representative	541.346.5593
Public Safety (Emergency)	541.346.6666
Public Safety (Non-Emergency)	541.346.2919

UO Human Physiology Temp Power Removal Shutdown Plan

4/12/21

Below is our plan for removing the temporary jobsite power from panel NW-LPC-2 at the UO human Physiology infill project.

4/28 7:30 AM:

- Turn off and lockout/tagout per UO requirement: 225A breaker in panel NW-HPC (circuits 1,3,5) feeding XFMR NW-LPC / Panel NW-LPC-2. See attached page for NW-LPC-2 panel schedule.
- Remove 200A feeder conductors from 200A breaker in Panel NW-LPC-2. Breaker to be left in panel as spare.

4/28 8:00 AM:

- Remove temporary flexible metal conduit from panel and seal knock-out hole.

4/28 8:30 AM:

- Remove lockout/tagout from 225A breaker in Panel NW-HPC and re-energize panel.

JKG onsite Contact:

Kyle Hansen
Foreman
541-214-0897



EC Powers Life

ALBANY REGIONAL OFFICE

32758 Old Hwy 34 S.E., Albany, Oregon 97322
For 24 hour Service Call: (541) 926-4266

PHASE IDENTIFICATION COLORS: BLACK-RED-BLUE

400 A SECT-2

208Y/120V

HAYWARD FIELD PANEL NW-LPC 2

SPARE	37	38	SPACE
REC, A/V RACK	39	40	SPACE
SPARE	41	42	SPACE
SPARE	43	44	HAND DRYER, WC 364
REC, 15TH AVE LT POLE	45	46	" "
REC, 15TH AVE LT POLE	47	48	BAS CTRL SYS, NW MECH
REC, 15TH AVE LT POLE	49	50	SPD
REC, 15TH AVE LT POLE	51	52	" "
SPARE	53	54	" "
REC, 4-POST RACK, COMM	55	56	SPARE
" "	57	58	SPARE
SPARE	59	60	SPACE
SPARE	61	62	SPARE
REC, A/V RACK	63	64	SPARE
REC, A/V RACK	65	66	SPACE
ACCESS CTRL SYS, RM 361	67	68	SPARE
SPARE	69	70	SPARE
SPARE	71	72	SPARE
SPARE	73	74	SPACE
SPACE	75	76	SPACE
SPACE	77	78	SPACE
SPACE	79	80	SPACE
SPACE	81	82	SPACE
SPACE	83	84	FLOW METER
SPACE	85	86	PANEL NW-LCA
SPACE	87	88	(125 A) "
SPACE	89	90	" "

11/18/04 11:11:11 AM